



NOTES

1. ALL PRODUCTS AND MATERIALS ARE TO BE NSF61 COMPLIANT.
2. METER AND METER ACCESSORIES TO BE SUPPLIED BY TOWN OF WOLFVILLE WATER UTILITY.
3. ALL PIPE MATERIAL IN THE WATER METER ARRANGEMENT IS REQUIRED TO BE TYPE K COPPER TUBING CONFORMING TO ASTM B88.
4. ALL NEW WATER SERVICE CONNECTIONS IN THE TOWN OF WOLFVILLE ARE REQUIRED TO BE PEXa. USE ASTM F877 COMPLIANT FITTING WITH STAINLESS STEEL INSERT TO TRANSITION THE TO THE COPPER TUBING OF THE WATER METER ARRANGEMENT.
5. WATER METER TO BE INSTALLED WITHIN 1200 mm OF WHERE THE SERVICE CONNECTION ENTERS THE BUILDING.
6. ARRANGEMENT IS TO BE NO LESS THAN 500 mm AND NO MORE THAN 1500 mm FROM THE FLOOR.
7. MINIMUM OF 1200 mm STRAIGHT LENGTH OF TYPE K COPPER TUBING IS REQUIRED DOWNSTREAM OF THE WATER METER. SECURE THE COPPER TUBING TO THE WALL OR FLOOR.
8. THE WATER METER ARRANGEMENT IS REQUIRED TO BE HORIZONTALLY LEVEL AND THE MINIMUM SPACING SPECIFIED FOR ACCESS.
9. ALL COMPONENTS ILLUSTRATED MUST BE INSTALLED PRIOR TO THE WATER METER INSTALLATION.
10. THE BUILDING IS REQUIRED TO BE ROOF TIGHT, AND THE CURB STOP AND SERVICE BOX ARE TO BE PLUMB AND LEVEL WITH THE FINAL GRADES AND FINISHED LANDSCAPING PRIOR TO WATER METER INSTALLATION.

 MUNICIPAL STANDARDS & SPECIFICATIONS	WATER METER ARRANGEMENT (UP TO 25mm SERVICE)	 Alexander J. de Sousa, P.Eng. DIRECTOR, ENGINEERING & PUBLIC WORKS	A.DE SOUSA	N.T.S.
	TITLE (ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE SHOWN)		APPROVAL	DRAWN BY 12/01/2023